

BACKFLOW PREVENTION DEVICE INVENTORY - June 05, 2018

Site:	Location:	Address:	Hazard Type:	Degree:	Device:	Size:	Brand:	Model:	Serial #:	Device Location:
1	Arts Academy	500 Washington Ave	Service	Moderate	RPZ	3/4"	Watts	909	542149	By mech room
2	Arts Academy	500 Washington Ave	Domestic	Moderate	RPZ	4"	Watts	994	115	By mech room
3	Arts Academy	500 Washington Ave	Fire	Moderate	RPDA	8"	Watts	909	4492	By mech room
4	Arts Academy	500 Washington Ave	Process	Moderate	RPZ	2"	Watts	909	N/A	Mech room
5	Bartlett Middle School	207 Montgomery Xrd	Service	High	RPZ	4"	Wilkins	575	B-14488	Front Mont XRds
6	Bartlett Middle School	207 Montgomery Xrd	Irrigation	Moderate	DC	1"	Wilkins	950 XL	13282	In front by meter
7	Bartlett Middle School	207 Montgomery Xrd	Process	Moderate	RPZ	3/4"	Watts	009M3	47282	Mech room
8	Bartlett Middle School	207 Montgomery Xrd	Process	Moderate	DC	3/4"	Wilkins	950XLT	13992	Mech room
9	Beach High School	3001 Hopkins St	Service	Moderate	DCA	3"	Watts	709	N/A	Eastside/property
10	Beach High School	3001 Hopkins St	Fire By-Pass	High	DC	3/4"	Watts	7m1	18756	In front of school
11	Beach High School	3001 Hopkins St	Domestic	Moderate	DC	3"	Watts	709	N/A	In front of gym
12	Beach High School	3001 Hopkins St	Fire	Moderate	DCDA	6"	Watts	709	111089	In front of school
13	Bloomingsdale Elementary	101 E Main St	Domestic	Moderate	RPZ	2"	Watts	9M2	171062	In front
14	Board of Education	208 Bull St	Irrigation	Moderate	DCA	2"	Wilkins	950	W76137	Inground pit North side
15	Brock Elementary School	1804 Stratford St	Service	Moderate	DCA	2"	Watts	9	3991	Front of School
16	Butler Elementary School	1909 Cynthia St	Fire By-Pass	Moderate	RPZ	3/4"	Watts	919	33840	North side of school
17	Butler Elementary School	1909 Cynthia St	Domestic	Moderate	DC	2"	Febco	850	H35707	North side of school
18	Butler Elementary School	1909 Cynthia St	Fire	High	RPDA	8"	Ames	500-GV	LG0312	North side of school
19	Coastal GA Comp Academy	2001 Cynthia St	Domestic	Moderate	DC	3"	Watts	709	N/A	In front by meter
20	Coastal Middle School	4595 Hwy 80	Domestic	Moderate	DC	4"	Watts	709	168652	Front mech room
21	Coastal Middle School	4595 Hwy 80	Fire	High	DCDA	4"	Watts	3000	131H01	In Kitchen
22	Coastal Middle School	4595 Hwy 80	Fire	High	DCDA	4"	Ames	3000	1018G19	Mech room
23	Coastal Middle School	4595 Hwy 80	Process	Moderate	DC	1 1/2"	Watts	709	N/A	Mech room
24	Derenne Middle School	1009 Clinch St	Fire By-Pass	Moderate	RPZ	3/4"	Watts	919	2884	By bus entrance
25	Derenne Middle School	1009 Clinch St	Domestic	Moderate	RPZ	4"	Watts	994	100507	By bus stop
26	Derenne Middle School	1009 Clinch St	Fire	High	RPDA	6"	Watts	994	823	By bus entrance
27	Derenne Middle School	1009 Clinch St	Irrigation	Moderate	RPZ	4"	Ames	994	6756	In field
28	Derenne Middle School	1009 Clinch St	Process	Moderate	RPZ	1"	Watts	909	531950	Mech room
29	Derenne Middle School	1009 Clinch St	Process	Moderate	RPZ	1"	Watts	909	29660	Mech room
30	East Broad Street School	400 E Broad St	Service	Moderate	DCA	2"	Watts	709	164830	W side/Front building
31	East Broad Street School	400 E Broad St	Irrigation	Moderate	PVC	2"	Febco	755-2	12130	W side of building
32	East Broad Street School	400 E Broad St	Chill Water	High	RPZ	2"	Watts	909	200291	In ceiling/Mech room
33	East Broad Street School	400 E Broad St	Process	Moderate	RPZ	3/4"	Watts	909	471283	Mech room
34	Ellis Elementary	220 E 49th St	Service	Moderate	RPZ	2 1/2"	Febco	825-Y	N/A	By fence on Capital St

35	Ellis Elementary	220 E 49th St	Fire By-Pass	Moderate	DC	3/4"	Watts	7M2	52678	In front by meter
36	Ellis Elementary	220 E 49th St	Domestic	Moderate	DC	3"	Watts	2000SS	117722	In front by meter
37	Ellis Elementary	220 E 49th St	Fire	High	DCDA	6"	Ames	3000SS	17948	In front by meter
38	Gadsden Elementary	919 May St	Service	Moderate	DCA	3"	Watts	7	781	North side of school
39	Garden City Elementary	4037 Kessler Ave	Domestic	Moderate	DC	4"	Wilkins	950	B12412	Gym
40	Garden City Elementary	4037 Kessler Ave	Fire	High	DC	4"	Ames	2000SS	2LK0158	Mech room
41	Garden City Elementary	4037 Kessler Ave	Fire	High	DC	4"	Ames	2000SS	2AL0099	Gym Mech room
42	Garden City Elementary	4037 Kessler Ave	Process	Moderate	RPZ	1 1/2"	Watts	009M2	121570	Mech room
43	Garrison Elementary	649 W Jones St	Boiler	High	RPZ	2"	Watts	9	709	In ceiling/Boiler room
44	Garrison Elementary	649 W Jones St	Irrigation	Moderate	DCA	1 1/2"	Watts	70907	133107	Janitors storage/Cafeteria
45	Garrison Elementary	649 W Jones St	Domestic	Moderate	DC	4"	Febco	805YD	B7335	In front by meter
46	Garrison Elementary	649 W Jones St	Irrigation	Moderate	DC	1 1/2"	Watts	7	22169	In front by meter
47	Garrison Elementary	649 W Jones St	Process	Moderate	DC	2"	Watts	709	90700	Mech room
48	Georgetown Elementary	1516 King George	Fire	Moderate	DCDA	4"	Watts	709	109295	Next To Back Door
49	Georgetown Elementary	1516 King George	Fire By-Pass	Moderate	DCA	3/4"	Watts	007 MQ7	14781	By pass on fire system
50	Georgetown Elementary	1516 King George	Cooling	Moderate	DCA	1 1/2"	Watts	7	12435	Ceiling Mechanical Room
51	Georgetown Elementary	1516 King George	Fire	Moderate	DCDA	4"	Febco	709	109795	
52	Georgetown Elementary	1516 King George	Fire By-Pass	Moderate	DCA	3/4"	Watts	007 MIOT	14777	By pass on fire system
53	Georgetown Elementary	1516 King George	Fire	High	DCDA	4"	Watts	709	109296	Mech room
54	Godley Sta K-8	2135 Benton Blvd	Fire By-Pass	Moderate	RPZ	3/4"	Watts	919	36985	In front by meter
55	Godley Sta K-8	2135 Benton Blvd	Domestic	Moderate	RPZ	6"	Watts	957	JH-1011	In front by meter
56	Godley Sta K-8	2135 Benton Blvd	Fire	High	RPDA	8"	Watts	957	JL-0977	In front by meter
57	Godley Sta K-8	2135 Benton Blvd	Irrigation	Moderate	RPZ	1 1/2"	Watts	009M2	131418	South side of school by meter
58	Godley Sta K-8	2135 Benton Blvd	Process	Moderate	RPZ	2"	Watts	009M2	275272	Mech room
59	Gould Elementary	4910 Pineland Dr	Fire By-Pass	Moderate	DCA	3/4"	Watts	7	7368	S/E corner of property
60	Gould Elementary	4910 Pineland Dr	Service	Moderate	DCA	4"	Febco	805-Y	19038	S/E corner of property
61	Gould Elementary	4910 Pineland Dr	Fire By-Pass	Moderate	DC	3/4"	Watts	7	73079	Behind café
62	Gould Elementary	4910 Pineland Dr	Fire	High	DCDA	6"	Ames	3000SS	DEL0050	Behind café
63	Groves High School	100 Wheathill Rd								
64	Groves High School	100 Wheathill Rd								
65	Groves High School	100 Wheathill Rd								
66	Groves High School	100 Wheathill Rd								
67	Groves High School	100 Wheathill Rd								
68	Heard Elementary	414 Lee Rd	Domestic	Moderate	DC	2"	Watts	709	3120	By café
69	Hesse Elementary	9116 Whitefield Ave	Service	Moderate	DCA	4"	Febco	805Y	B18194	
70	Hesse Elementary	9116 Whitefield Ave	Domestic	Moderate	DC	4"	Febco	805Y	B18194	In front
71	Hodge Elementary	3609 Hopkins	Domestic	Moderate	DC	2 1/2"	Wilkins	950	82913	SE corner of propety

72	Hodge Elementary	3609 Hopkins	Domestic	Moderate	DC	2"	Watts	7M1	177310	SE corner of property
73	Hodge Elementary	3609 Hopkins								
74	Howard Elementary	115 Willmington Is Rd	Domestic	Moderate	RPZ	1 1/2"	Watts	9M2	72510	Next to office
75	Hubert Middle School	768 Grant Street	Service	Moderate	DCA	4"	Febco	805	B18240	Behind Kitchen area
76	Hubert Middle School	768 Grant Street	Domestic	Moderate	DC	4"	Febco	805	B18240	By lunch room
77	Islands High	170 Whitmarsh Is Rd	Irrigation	Moderate	DC	2"	Conbraco	40-100	626067	Bus loading area
78	Islands High	170 Whitmarsh Is Rd	Process	Moderate	RPZ	1"	Watts	9M2	A16341	Mech room
79	Jenkins High School	1800 DeRenne Ave	Irrigation	Moderate	DCA	3"	Watts	709	123599	Front of School
80	Jenkins High School	1800 DeRenne Ave	Domestic	Moderate	DC	3"	Conbraco	DC	M2049	By gym
81	Johnson High	3012 Sunset Blvd	Fire By-Pass	Moderate	DC	3/4"	Ames	2000B	8021	Back parking lot
82	Johnson High	3012 Sunset Blvd	Domestic	Moderate	RPZ	3"	Ames	4000SS	4JN1172	Back parking lot
83	Johnson High	3012 Sunset Blvd	Fire	High	DCDA	8"	Ames	3000SS	3H10958	Back parking lot
84	Johnson High	3012 Sunset Blvd	Process	Moderate	RPZ	1 1/2"	Watts	9	30746	Mech room
85	Largo Tiget Elementary	430 Tibet Ave	Service	Moderate	DCA	3"	Ames	2000	2G1013	In front S/W corner
86	Largo Tiget Elementary	430 Tibet Ave	Domestic	Moderate	DC	3"	Ames	2000SS	2G10130	In front by meter
87	Largo Tiget Elementary	430 Tibet Ave	Domestic	Moderate	DC	2"	Watts	7M1	193544	In front of school
88	Largo Tiget Elementary	430 Tibet Ave	Irrigation	Moderate	RPZ	2"	Watts	9M2	296654	In front of school
89	Low Elementary	15 Blue Ridge Dr	Service	Moderate	DCA	3"	Watts	709	125093	N/E corner of boiler room
90	Maintenance & Operations	2219 Gamble Road	Service	High	RPZ	4"	Ames	4000	102414	Rightside/M. Gate
91	Marshpoint Elementary	135 Whitmarsh Rd	Service	Moderate	RPZ	1 1/2"	Watts	9	88721	Mech room ceiling
92	Marshpoint Elementary	135 Whitmarsh Rd	Domestic	Moderate	DC	4"	Watts	774	108962	In front by meter
93	Massie Heritage Center	207 E Gordon St	NO BACKFLOW PREVENTER PRESENT				N/A	N/A	N/A	N/A
94	Mercer Middle	201 Rommel Ave	Fire By-Pass	Moderate	DC	3/4"	Febco	805YB	A7328	Mech room
95	Mercer Middle	201 Rommel Ave	Domestic	Moderate	RPZ	4"	Wilkins	375	N/A	Front storage room
96	Mercer Middle	201 Rommel Ave	Fire	High	DCDA	4"	Febco	876V	9805121312	Mech room
97	Mercer Middle	201 Rommel Ave	Process	Moderate	RPZ	1 1/2"	Wilkins	975XL	530108	Mech room
98	Myers Middle	2025 E 52nd St	Fire By-Pass	Moderate	RPZ	3/4"	Ames	4000B	2515	In front by meter
99	Myers Middle	2025 E 52nd St	Fire By-Pass	Moderate	RPZ	3/4"	Ames	4000B	2504	In rear of school
100	Myers Middle	2025 E 52nd St	Domestic	Moderate	RPZ	4"	Watts	994	100780	In front by meter
101	Myers Middle	2025 E 52nd St	Domestic	Moderate	RPZ	4"	Watts	994	100796	In rear of school
102	Myers Middle	2025 E 52nd St	Fire	High	RPDA	6"	Watts	994	100478	In front by meter
103	Myers Middle	2025 E 52nd St	Fire	High	RPDA	6"	Ames	5000SS	100564	In rear of school
104	Myers Middle	2025 E 52nd St	Irrigation	Moderate	DC	4"	Watts	774	102158	In front by meter
105	Myers Middle	2025 E 52nd St	Process	Moderate	RPZ	1"	Wilkins	975XL	744287	Mech room
106	Myers Middle	2025 E 52nd St	Process	Moderate	RPZ	1"	Wilkins	975XL	782441	Mech room
107	New Coastal Middle School	4595 US Hwy 80 E	Fire By-Pass	Moderate	DCA	3/4"	Watts	7	693	Mech room
108	New Coastal Middle School	4595 US Hwy 80 E	Fire By-Pass	Moderate	DCA	3/4"	Watts	7	3209	Mech room

109	New Hampstead High	2451 Little Neck Rd	Fire By-Pass	Moderate	DC	3/4"	Watts	7	N/A	Across from FD connection
110	New Hampstead High	2451 Little Neck Rd	Domestic	Moderate	RPZ	6"	Watts	994	1003930811	Across from FD connection
111	New Hampstead High	2451 Little Neck Rd	Fire	High	DCDA	8"	Watts	774	N/A	Across from FD connection
112	New Hampstead High	2451 Little Neck Rd	Irrigation	Moderate	RPZ	3"	Wilkins	375	L72958	Across from FD connection
113	New Islands High School	170 Whitmarsh Is Rd	Service	Moderate	RPZ	6"	Combraco	40-200	N4710	SW side of building
114	New Islands High School	170 Whitmarsh Is Rd	Service	High	RPZ	1"	Watts	909	432728	In mechanical room near ceiling
115	New Islands High School	170 Whitmarsh Is Rd	Service	High	RPZ	3/4"	Watts	009M2	90889	In ceiling in Janitor closet
116	New Islands High School	170 Whitmarsh Is Rd	Service	High	RPZ	3/4"	Watts	009M2	90817	In mechanical room near ceiling
117	New Islands High School	170 Whitmarsh Is Rd	Service	High	RPZ	3/4"	Watts	009M2	90812	In mechanical room near ceiling
118	Oglethorpe Charter	7202 Central Ave	Fire By-Pass	Moderate	DC	3/4"	Watts	7M2	19739	North side of school
119	Oglethorpe Charter	7202 Central Ave	Domestic	Moderate	RPZ	4"	Watts	994	104044	North side of school
120	Oglethorpe Charter	7202 Central Ave	Fire	High	DCDA	8"	Watts	774	1343360871	North side of school
121	Oglethorpe Charter	7202 Central Ave	Irrigation	Moderate	RPZ	2"	Febco	860	H19085	North side of school
122	Oglethorpe Charter	7202 Central Ave	Process	Moderate	RPZ	1"	Wilkins	975XL	3274472	Mech room
123	Oglethorpe Charter	7202 Central Ave	Process	Moderate	RPZ	2"	Wilkins	957	3609057	Mech room
124	Pt. Wentworth Elementary	507 S Coastal Hwy	Service	High	RPZ	3"	Watts	909	N/A	In front
125	Pulaski Elementary	5330 Montgomery St	Service	Moderate	DCA	3/4"	Watts	7	6570	Left side of entrance way
126	Pulaski Elementary	5330 Montgomery St	Service	Moderate	DCA	2"	Watts	7	10738	Left side of entrance way
127	Pulaski Elementary	5330 Montgomery St	Fire	Moderate	7 Dual	1"	Watts	No 7	1237881	7 Systems see files
128	Pulaski Elementary	5330 Montgomery St	Service	High	RPZ	2"	Watts	9	86891	Meter box left of flagpole
129	Pulaski Elementary	1001 Tibet Ave	Fire By-Pass	Moderate	RPZ	3/4"	Watts	4000B	10564	Right side of entrance
130	Pulaski Elementary	1001 Tibet Ave	Domestic	Moderate	DC	6"	Wilkins	350	N35296	Right side of entrance
131	Pulaski Elementary	1001 Tibet Ave	Fire	High	RPZ	10"	Wilkins	375	L65248	Right side of entrance
132	Pulaski Elementary	1001 Tibet Ave	Irrigation	Moderate	RPZ	2"	Watts	9M2	A101127	In bus ramp area
133	Pulaski Elementary	1001 Tibet Ave	Process	Moderate	RPZ	2"	Wilkins	975XL	3416520	Mech room
134	Pulaski Elementary	1001 Tibet Ave	Process	Moderate	RPZ	1"	Apollo	RP40	288356	Mech room
135	Savannah High School	400 Pennsylvania Ave	Fire	Moderate	DCDA	8"	Wilkins	950	2314	In pit s/side of school
136	Savannah High School	400 Pennsylvania Ave	Fire By-Pass	Moderate	DCA	3/4"	Wilkins	950	412079	In pit s/side of school
137	Savannah High School	400 Pennsylvania Ave	Service	High	RPZ	2"	Watts	9		In mech room near ceiling
138	Savannah High School	400 Pennsylvania Ave	Service	Moderate	RPZ	4"	Watts	909	251377	S/E corner of school
139	Savannah High School	400 Pennsylvania Ave	Fire By-Pass	Moderate	DC	3/4"	Wilkins	950XL	410279	Bus loading area
140	Savannah High School	400 Pennsylvania Ave	Domestic	Moderate	RPZ	4"	Watts	909	251377	By chiller
141	Savannah High School	400 Pennsylvania Ave	Fire	High	DCDA	6"	Wilkins	950	D02314	Bus loading area
142	Savannah High School	400 Pennsylvania Ave	Irrigation	Moderate	DC	2"	Watts	9M2	A03325	In ball field
143	Savannah High School	400 Pennsylvania Ave	Process	Moderate	RPZ	2"	Watts	909	110055	Mech room
144	Shuman Middle	415 Gobel Ave	Service	High	RPZ	4"	Wilkins	975	B100060	In pit southside driveway
145	Shuman Middle	415 Gobel Ave	Process	Moderate	RPZ	1"	Watts	9	410279	Gym Mech room

146	Smith Elementary	210 Lamar Ave	Domestic	Moderate	DC	3"	Febco	805YD	B18562	In front
147	Southwest Elementary	6020 Ogeechee Rd	Fire	Moderate	DCDA	6"	Ames	3000	3HN0974	In front of wings 3& 5
148	Southwest Elementary	6020 Ogeechee Rd	Fire By-Pass	Moderate	DCA	3/4"	Ames	2000	6741	In front of wings 3& 5
149	Southwest Elementary	6020 Ogeechee Rd	Service	Moderate	DCA	3"	Ames	2000	21N1540	In front of wings 3& 5
150	Southwest Elementary	6020 Ogeechee Rd	Fire By-Pass	Moderate	DC	3/4"	Ames	2000B	6804	Bus loading area
151	Southwest Elementary	6020 Ogeechee Rd	Fire	High	DCDA	6"	Ames	3000SE	341075	Bus loading area
152	Southwest Elementary	6020 Ogeechee Rd	Process	Moderate	RPZ	3/4"	Wilkins	975XL	784785	Mech room
153	Southwest Elementary	6020 Ogeechee Rd	Process	Moderate	RPZ	3/4"	Wilkins	975XL	784802	Mech room
154	Southwest Middle	6030 Ogeechee Rd	Service	High	RPZ	6"	Ames	4000	4LN-1176	NW side of building
155	Southwest Middle	6030 Ogeechee Rd	Service	Moderate	RPZ	2"	Febco	975	514725	In
156	Southwest Middle	6030 Ogeechee Rd	Other	Moderate	RPZ	3/4"	Febco	975XL	627951	Room 712
157	Southwest Middle	6030 Ogeechee Rd	Other	Moderate	RPZ	3/4"	Febco	975XL	628114	Room 822
158	Southwest Middle	6030 Ogeechee Rd	Fire By-Pass	Moderate	DC	3/4"	Febco	805Y	N/A	Behind school
159	Southwest Middle	6030 Ogeechee Rd	Process	Moderate	RPZ	1"	Febco	975	321168	Mech room
160	Southwest Middle	6030 Ogeechee Rd	Fire	Moderate	DCDA	8"	Febco	805YD	3370	NW side of building
161	Southwest Middle	6030 Ogeechee Rd	Other	Moderate	RPZ	3/4"	Febco	975XL	628122	Room 723
162	Thunderbolt Elementary	3313 Louis St								
163	Thunderbolt Elementary	3313 Louis St								
164	West Chatham Elementary	820 Pine Barren Rd								
165	West Chatham Elementary	820 Pine Barren Rd								
166	West Chatham Elementary	820 Pine Barren Rd								
167	West Chatham Middle	800 Pine Barren Rd								
168	West Chatham Middle	800 Pine Barren Rd								
169	West Chatham Middle	800 Pine Barren Rd								
170	West Chatham Middle	800 Pine Barren Rd								
171	White Bluff Elementary	9402 White Bluff Rd	Domestic	Moderate	DC	3"	Watts	709	125100	By bus entrance
172	Whitney Complex	2 Laura Street	Fire By-Pass	Moderate	DC	3/4"	Watts	7M1	59049	Along New Mexico
173	Whitney Complex	2 Laura Street	Domestic	Moderate	RPZ	2 1/2"	Febco	825YD	9409260634	Along Capitol St
174	Whitney Complex	2 Laura Street	Fire	High	DCDA	6"	Ames	3000SS	130903	Along New Mexico
175	Windsor Forest Elementary	414 Briar Cliff Rd		Moderate	DCDA	6"	Ames	3000SS	3DU0817	3/4 DC by pass on 6" Backflow
176	Windsor Forest Elementary	414 Briar Cliff Rd		Moderate	DC	3/4"	Watts	007M2QT	18630	Concrete box closest to school
177	Windsor Forest Elementary	414 Briar Cliff Rd	Domestic	Moderate	RPZ	2"	Febco	860	H16344	In front of community center
178	Windsor Forest Elementary	414 Briar Cliff Rd	Domestic	Moderate	RPZ	4"	Ames	4000SS	4BJ0498	In front of community center
179	Windsor Forest High School	12419 Largo Dr	Service	Moderate	DCA	3"	Hersey		303481	In front
180	Windsor Forest High School	12419 Largo Dr	Fire By-Pass	Moderate	DC	3/4"	Watts	7M2	17387	In front of school
181	Windsor Forest High School	12419 Largo Dr	Fire By-Pass	Moderate	RPDA	3/4"	Wilkins	375	N/A	In front of school by exit
182	Windsor Forest High School	12419 Largo Dr	Domestic	Moderate	RPZ	4"	Wilkins	374	N/A	In front of school by exit

183	Windsor Forest High School	12419 Largo Dr	Fire	High	DCDA	8"	Watts	774	1113590907	In front of school
184	Windsor Forest High School	12419 Largo Dr	Fire	High	RPSA	6"	Wilkins	375	N/A	In front of school by exit
185	Woodville-Thompkins	151 Coach Joe Turner	Irrigation	Moderate	DC	3/4"	Watts	7	39115	West side of school
186	Woodville-Thompkins	151 Coach Joe Turner	Domestic	Moderate	RPZ	3"	Ames	4000SS	4D00712	West side of school
187	Woodville-Thompkins	151 Coach Joe Turner	Fire	High	DCDA	6"	Ames	3000SS	3N0978	West side of school
188	Woodville-Thompkins	151 Coach Joe Turner	Process	Moderate	RPZ	1"	Watts	909	86403	Mech room
189	Woodville-Thompkins Annex	Picilla Thomas Way								